

**ADDENDUM #1 TO CONTRACT DOCUMENTS****INVITATION TO BID
ITB #19-07-382**

****This Addendum MUST be acknowledged via the “Addendum Acknowledgement Form” in ITB****

Addendum Date: August 12, 2019

TO ALL PROSPECTIVE BIDDERS:

Bidders, for the above referenced project, shall take note of the following revisions, additions, deletions, clarifications, etc. relative to the ITB, which in accordance with the Contract Documents shall become a part of and have precedence over anything shown or described otherwise.

Responses to Questions

D Electrician	
QUESTION(S)	RESPONSE(S)
Section 2 scope state “ 500-year storm event” please clarification that requirement never heard of such generator sepc	This is a risk assessment tool used by insurance companies that indicates there is a 1 in 500 chance of flooding happening in any year. Provide the mounting system as specified.
Will there be any pre bid meeting	There is no pre-bid meeting as this ITB is for products.
What is the current size electrical services at the Lift Station location?	None, the ITB is for portable generators.
Where is the ACTUAL LIFT STATION LOCATION	The ITB is for portable generators which are intended to be moved between six (6) lift station: LS 1 – 6491 Kimberly Boulevard LS 2 – 6045 Kimberly Boulevard LS 3 – 1201 SW 52 nd Avenue LS 7 – Forest Boulevard & SW 73 rd Avenue LS 9 – SW 5 th Street & SW 76 th Avenue LS 16 - 8051 Southgate Boulevard
What is the power factor of the units	The generators will be 375 KW @ 60 Hz



Do you need tool box on the trailer if so what is the size	No tool box is needed
State license electrical contractor	This bid is for the purchase of portable generator sets. No electrical work is required.
Do you need cam lok and sJ cable for hoop up	Standard cam lock connectors

All other documents, specifications, drawings, terms and conditions remain the same.

END OF DOCUMENT